



Marine Design Appraisal Document

Lloyd's Register North America, Inc.
Miami Design Support Office
Suite 530
1000 S. Pine Island Road
Plantation, FL 33324

Date
25 January 2010

Quote this reference on all future communications
MDSO/JV/O-10016

ATTACHMENT TO CERTIFICATE OF TYPE APPROVAL No. LRTC 10-60003 (E2)

Roxul Inc. - Fire Resisting Material – Type: "Roxul Tecton 1200 Mineral Wool Pipe Insulation" (density 104kg/m³)

This Design Appraisal Document forms part of the Certificate LRTC 10-60003 (E2).

APPROVAL DOCUMENTATION

This certificate is issued on basis of Lloyd's Register Certificate of Fire Approval Cert No. SAS F090282 and the tests listed there in.

CONDITIONS OF CERTIFICATION

1. Product consists of rock fibre pipe insulation (density 104kg/m³)
2. Production items are to be manufactured in accordance with a quality control system which shall be maintained to ensure that items are of the same standard as the approved prototype.

PLACE OF PRODUCTION

Roxul Inc.
6526 Industrial Pakway
Grand Forks, BC
Canada V0H1H0

FINAL ACCEPTANCE OF ACTUAL ITEM(S) DEPEND(S) ON SATISFACTORY SURVEY AND TESTING

Lloyd's Register North America, Inc.
is a member of the Lloyd's Register Group

Lloyd's Register, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as the 'Lloyd's Register Group'. The Lloyd's Register Group assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register Group entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.

Lloyd's Register North America, Inc.
Miami Design Support Office
Suite 530
1000 S. Pine Island Road
Plantation, FL 33324

Date
25 January 2010

Quote this reference on all future communications
MDSO/JV/O-10016

Supplementary Type Approval Terms and Conditions

Type Approval certifies that a representative sample of the product(s) referred to herein have been found to meet the applicable design criteria for the use specified herein. It does not mean or imply approval for any other use, nor approval of any product(s) designed or manufactured otherwise than in strict conformity with the said representative sample. Type Approval is based on the understanding that the manufacturer's recommendations and instructions and any relevant requirements of the Rules and Regulations are complied with. Type Approval does not eliminate the need for normal inspection and survey procedures required by the Rules and Regulations. Lloyd's Register North America, Inc. reserves the right to cancel or withdraw this Type Approval Certificate in accordance with the Lloyd's Register Type Approval System Procedure.



Jeremy Vecchione
Surveyor
Miami Design Support Office
Office: +1 954 236 8366
Fax: +1 954 452 3306
Jeremy.Vecchione@lr.org

FINAL ACCEPTANCE OF ACTUAL ITEM(S) DEPEND(S) ON SATISFACTORY SURVEY AND TESTING

Lloyd's Register North America, Inc.
is a member of the Lloyd's Register Group