



**DESIGN APPRAISAL DOCUMENT**

Date 7 September 2009	Quote this reference on all future communications LDSS/TA/SFS/SA
--------------------------	---

**ATTACHMENT TO CERTIFICATE OF TYPE APPROVAL No. SAS F090282**

This Design Appraisal Document forms part of the Certificate.

**APPROVAL DOCUMENTATION**


Southwest Research Institute (SwRI), Texas, USA Fire Test Report No. 01.06061.01.603c, dated January 2003.

**CONDITIONS OF CERTIFICATION**

1. Product consists of rock fibre pipe insulation (density 104kg/m<sup>3</sup>)
2. Production items are to be manufactured in accordance with a quality control system which shall be maintained to ensure that items are of the same standard as the approved prototype.

**PLACE OF PRODUCTION**

Roxul Inc.  
551 Harrop Drive  
Milton, ON  
Canada L9T 3H3



Saji Abraham  
Surveyor  
Statutory Fire and Safety  
London Design Support Services  
Lloyd's Register EMEA

**Supplementary Type Approval Terms and Conditions**

*This certificate and Design Appraisal Document relates to type approval, it certifies that the prototype(s) of the product(s) referred to herein has/have been found to meet the applicable design criteria for the use specified herein, it does not mean or imply approval for any other use, nor approval of any products designed or manufactured otherwise than in strict conformity with the said prototype(s).*